

Stair and Guardrail Requirements

Stairs: (a) 8 ¼" max riser height, 4" min (b) 9" Min treads measured leading edge to leading edge (c) treads and risers shall be uniform (d) handrails shall be graspable per code (e) handrails shall be 30" to 38" above tread nose.

Guardrails: (a) 36" min height (b) baluster spacing shall not permit the passage of a 4" sphere.