



FREEHOLD SOIL CONSERVATION DISTRICT

(Serving Middlesex and Monmouth Counties)

4000 Kozloski Road, P.O. Box 5033

Freehold, New Jersey 07728-5033

Tel: (732) 683-8500

Fax: (732) 683-9140

E-mail: info@freeholdscd.org

Website: www.freeholdsoil.org

M & M AT NEPTUNE, LLC
1260 STELTON ROAD
PISCATAWAY NJ 08854

6/5/20

Ref.#: 2010-0938
Proj.: M & M AT NEPTUNE
Twp. : NEPTUNE TOWNSHIP
Block: 701
Lots : 1

REVIEW OF CERTIFIED PLAN REVISIONS

We have conducted our review of the revisions submitted for the above referenced application and find them incomplete. The following deficiencies must be addressed in order for the application to be complete.

1. Graphically identify and label all proposed stormwater piping, inlets, outlet structures, basins and other applicable stormwater facilities on the erosion control plan view. The aforementioned details are depicted on the 'Drainage Plan' (sheet 9 of 23) and designer may consider incorporating three sealed copies of the Drainage Plan with the erosion control set of plans. Make all necessary modifications.

Please incorporate the above items on to a revised Soil Erosion and Sediment Control Plan and forward three (3) sets, along with supporting calculations in accordance with the State Standards for Soil Erosion and Sediment Control if required, to our office for further review. Upon review and determination that the items have been correctly and completely addressed, the application will be considered complete and recommended for certification. Failure to resubmit the above referenced items may result in a determination of project non-compliance. Such non-compliance may result in the withholding of Reports of Compliance or the issuance of a **STOP CONSTRUCTION ORDER**. If you have any questions, please contact us.

Sincerely,


Michael Infanti
Resource Conservationist II

CC: Applicant's Engineer
Planning Board