



## FREEHOLD SOIL CONSERVATION DISTRICT

(Serving Middlesex and Monmouth Counties)

4000 Kozloski Road, P.O. Box 5033  
Freehold, New Jersey 07728-5033  
Tel: (732) 683-8500  
Fax: (732) 683-9140  
E-mail: [info@freeholdscd.org](mailto:info@freeholdscd.org)  
Website: [www.freeholdsoil.org](http://www.freeholdsoil.org)

M & M AT NEPTUNE, LLC  
1260 STELTON ROAD  
PISCATAWAY NJ 08854

4/27/21

Ref.#: 2019-0938  
Proj.: M & M AT NEPTUNE  
Twp. : NEPTUNE TOWNSHIP  
Block: 701  
Lots : 1

### REVIEW OF CERTIFIED PLAN REVISIONS

We have conducted our review of the revisions submitted for the above referenced application and find them incomplete. The following deficiency must be addressed in order for the application to be complete.

1. Submit design support calculations for the proposed scour hole in accordance with the State Standard for Conduit Outlet Protection. Modify the preformed scour hole detail on Drawing C-18 as necessary and be sure to include all site specific dimensions and d50 rip rap size. Include the overall dimensions and thickness in accordance with the details and design criteria of the state standard.

Please incorporate the above items on to a revised Soil Erosion and Sediment Control Plan and forward three (3) sets, along with supporting calculations in accordance with the State Standards for Soil Erosion and Sediment Control if required, to our office for further review. Upon review and determination that the items have been correctly and completely addressed, the application will be considered complete and recommended for certification. Failure to resubmit the above referenced items may result in a determination of project non-compliance. Such non-compliance may result in the withholding of Reports of Compliance or the issuance of a **STOP CONSTRUCTION ORDER**. If you have any questions, please contact us.

Sincerely,

  
Michael Infanti  
Resource Conservationist II

Cc: Applicant's Engineer  
Planning Board