



NEPTUNE FIRE PREVENTION BUREAU



P.O. BOX 457
NEPTUNE, NJ 07754-0457
(732) 988-8510
FAX (732) 988-8774

Sean Donohue
FIRE OFFICIAL

October 27, 2021

Kristie Dickert
Land Use Board Office
Neptune, NJ 07753

Re: Victoria Gardens
Block 4001, Lots 1, 2 & 3
Hovchild Boulevard

Kristie:

I apologize for the delayed response as the plans for Victoria Gardens just came across my desk.

In review, I have the following concerns:

The model fire truck used in the drawings has a length of 41 feet. The Neptune Fire Department's longest ladder truck is 50 feet in length. This will need to be taken into account on the vehicle circulation plan and potential fire zone placement.

There are six fire hydrants proposed, will these be on a private fire water main or public main? If this will be a public main, the Fire District will need notification in order to pass resolutions to add these.

Please include the attached fire hydrant specifications for hydrant installations.

Yours in fire safety,

Sean T. Donohue
Fire Official





NEPTUNE FIRE PREVENTION BUREAU



P.O. BOX 457
NEPTUNE, NJ 07754-0457
(732) 988-8510
FAX (732) 988-8774

Sean Donohue
FIRE OFFICIAL

Specifications for Fire Hydrants

Neptune Fire District #1

Opens:	Right
Operating Nut:	1 ½ Pentagon
Hose Nozzles:	2 – 2 ½ inch
Pumper Nozzle:	1 – 4 inch
Threads per Inch:	6
Maj. Dia.:	4.837
Pitch Dia.:	4.716
Minor Dia:	4.592
Iowa Sizer:	#6

*Specs provided by NJ American Water (4/2021)

