



# NEPTUNE FIRE PREVENTION BUREAU



P.O. BOX 457  
NEPTUNE, NJ 07754-0457  
(732) 988-8510  
FAX (732) 988-8774

Sean Donohue  
FIRE OFFICIAL

July 17, 2023

To: Neptune Township Land Use Board

Re: Block 3101, Lot 4 (Galilee Eglise Adventiste Church))

In review of the plans for the above proposed development, I have the following concerns:

- Based on square footage of basement area the following may be required:
  - o Fire sprinklers
  - o Fire hydrant on site
  - o Fire alarm system
  - o Knox Key Access Box
- Fire lanes will be required
  - o 25 feet wide per ordinance
- Basement kitchen
  - o If grease laden vapors will be produced, a hood ventilation system and fire suppression system may be required.

Yours in fire safety,

Sean Donohue  
Fire Official

